

2003 AUSTRALIAN NOISE EXPOSURE INDEX - Gold Coast Airport Forecast

Building Type	ANEF zone of site		
	Acceptable	Conditionally acceptable	Unacceptable
Home, home unit, flat, caravan park	Less than 20 ANEF (note 1)	20 to 25 ANEF (note 2)	Greater than 25 ANEF
Hotel, motel, hostel	Less than 25 ANEF	25 to 30 ANEF	Greater than 30 ANEF
School, university	Less than 20 ANEF (note 1)	20 to 25 ANEF (note 2)	Greater than 25 ANEF
Hospital, nursing	Less than 20 ANEF (note 1)	20 to 35 ANEF	Greater than 25 ANEF
Public building	Less than 20 ANEF (note 1)	20 to 30 ANEF	Greater than 30 ANEF
Commercial building	Less than 25 ANEF	25 to 35 ANEF	Greater than 35 ANEF
Light industrial	Less than 30 ANEF	30 to 40 ANEF	Greater than 40 ANEF
Other industrial	Acceptable in all ANEF Zones		

Note. Updated 2009 forecast will be available in January 2012

This map is a guide only. Contact ANACC for more accurate information: anacc@gcal.com.au

